

Side Tie



General Recommendations



Side Ties are designed and manufactured to secure conductors to the side groove of the insulator.

Side Ties provide an improved method of securing conductors compared to hand ties. Side Ties provide superior abrasion protection for the conductor under all types of motion, including low frequency sway oscillation, high frequency aeolian vibration and galloping.

The neoprene component surrounds the bare conductor with a resilient cushioning where the conductor would come into contact with the insulator and with the centre section of the tie. In the case of Side Ties being applied over Armor Rods, the tube can be disposed of, as contact with the bare conductor is prevented by the Armor Rod.



On vertically mounted insulators, Side Ties can normally accommodate line angles of up to 40° depending upon the angle of the insulator and orientation. In all cases the conductor should rest in the preferred insulator groove, independently of the tie, so the tie is not required to force the conductor to remain in the groove.

Due to the construction of Side Ties, if an impact load is applied to one side of the insulator and then released, the side ties retains a memory and will return to its original position.

For Application Procedures, visit the PLP website.

www.preformed.com.au


SAFETY CONSIDERATIONS

- This product is intended for a single (one-time) use and for the specified application, although it may be re-applied twice for retensioning within 90 days from initial installation.
- Do not modify this product in any way.
- This product is intended for use by qualified linesmen only.
- When working in the area of energised line with this product, extra care should be taken to prevent accidental electrical contact.
- For proper performance and personal safety, be sure to select the proper size PREFORMED™ products before application.
- PREFORMED™ products are precision devices. To ensure proper performance, they should be stored in cartons under cover and handled carefully.

Side Tie



For AAC, AAAC and ACSR over Bare Conductor



Fittings to suit 112mm neck insulators are available, substitute suffix -76 for -112

Part Number	Conductor Diameter Range (mm)	Colour Code
AWST-053-76	4.80 - 5.49	Purple
AWST-060-76	5.50 - 6.19	Brown
AWST-068-76	6.20 - 7.03	Brown
AWST-075-76	7.04 - 7.99	Blue
AWST-090-76	8.00 - 9.06	Red
AWST-102-76	9.07 - 10.29	Purple
AWST-113-76	10.30 - 11.65	Purple
AWST-125-76	11.66 - 13.19	Orange
AWST-140-76	13.20 - 14.99	Blue
AWST-163-76	15.00 - 17.19	Orange
AWST-180-76	17.20 - 19.19	Black
AWST-210-76	19.20 - 21.69	Red
AWST-220-76	21.70 - 22.59	Green
AWST-240-76	22.60 - 24.59	Red
AWST-255-76	24.60 - 25.60	Orange
AWST-290-76	27.80 - 31.40	Black

Insulator Colour Codes:

76mm neck - Yellow
112mm neck - Blue

For SC/GZ Conductors over Bare Conductor



These Side Ties are designed to be applied over PLP Preformed Armor Rods. These are the preferred package for the support point on medium to long spans in distribution and medium voltage line designs. The package gives maximum protection and holding capacity at the support point, where wind sway or arc-over could be considered a problem. Where there is a known vibration issue, it is highly recommended that a PLP spiral damper (SVD) be installed.

Fittings to suit 76mm and 112mm neck insulators are available, substitute suffix -54 for -76 or 112 respectively.

Part Number	Conductor Stranding	Conductor Diameter (mm)	Colour Code
GST-043-54	3/2.00	4.31	Yellow
GST-048-54	7/1.60	4.80	Black
GST-055-54	3/2.75	5.93	White
GST-060-54	3/2.75 7/2.00	5.91 6.00	White Yellow
GST-083-54	7/2.75	8.25	White
GST-098-54	7/3.25	9.75	Orange
GST-102-54	19/2.00	10.00	Yellow
GST-113-54	7/3.75	11.30	Black
GST-120-54	7/4.00	12.00	Black
GST-138-54	19/2.75	13.80	White


Insulator Colour Codes:

54mm neck - Red
76mm neck - Yellow
112mm neck - Blue

Side Tie



For AAC, AAAC and ACSR over Armoured conductor



Fittings to suit 112mm neck insulators are available, substitute suffix -76 for -112

Part Number (Side Tie)	Part Number (Armor Rods)	Conductor Stranding	Conductor Diameter (mm)
AWST-113A-76	AAR-053	7/1.75	5.25
AWST-125A-76	AAR-063	7/2.00	6.00
AWST-140A-76	AAR-075	7/2.50	7.50
AWST-163A-76	AAR-090	7/3.00	9.00
AWST-210A-76	AAR-113	7/3.75	11.25
AWST-220A-76	AAR-135	7/4.50	13.50
AWST-240A-76	AAR-143	7/4.75	14.25
AWST-255A-76	AAR-163	19/3.25	16.25
AWST-270A-76	AAR-175	30/7/2.50	17.50
AWST-290A-76	AAR-188	19/3.75	18.75

Insulator Colour Codes:
76mm neck - Yellow
112mm neck - Blue

NOTE: The range of a tie for armoured conductor is the diameter with armouring not the bare conductor.



Note: Typical Armor-Rods to be used with the above ties.

For Galvanised Steel Conductors (SC/GZ)



Fittings to suit 76mm and 112mm neck insulators are available, substitute suffix -54 for -76 or -112 respectively.

Part Number (Side Tie)	Part Number (Armor Rods)	Conductor Stranding	Conductor Diameter (mm)
GST-083A-54	GAR-038	3/2.00	4.31
GST-090A-54	GAR-043	7/1.60	4.80
GST-102A-54	GAR-055	3/2.75	5.93
GST-104A-54	GAR-060	7/2.00	6.00
GST-138A-54	GAR-083	3/4/2.50	7.50
GST-160A-54	GAR-098	7/3.25	9.75
	GAR-100	19/2.00	10.00

Insulator Colour Codes:
54mm neck - Red
76mm neck - Yellow
112mm neck - Blue

NOTE: The range of a tie for armoured conductor is the diameter with armouring not the bare conductor.



Note: Typical Armor-Rods to be used with the above ties.




Application Procedure & Safety Considerations

PREFORMED LINE PRODUCTS

SIDE TIE

Completely read and understand this procedure before applying products. Special attention should be given to the Safety Considerations located on the last page. We advise the reader to review those considerations now, and then again during the general review of this procedure.

These products are designed and tested to be used only on insulators complying with the dimensional requirements of AS2947.2 – 1989.



SIDE TIE as received in the field.

NOTE: Tie pad may be covering insulator identification mark.


COLD APPLICATION

- 1) PREFORMED Side Tie and Tie Pad.




- 2) Apply Tie Pad conductor, slit facing up, so that conductor does not come into direct contact with the insulator.






- 3) Tie Pad in position. Note that the conductor does not touch the insulator.



- 4) Squeeze the legs of the Side Tie together. This will enlarge the loop enabling it to be pushed over the head of the insulator.




- 5) Position the Side Tie around the neck of the insulator, making certain the conductor is between the legs of the Side Tie.




- 6) Pull the legs of the Side Tie firmly in opposite directions and start to wrap onto the conductor. On larger size conductors, it is optional whether the legs of the tie go under or over the tie pad.




6a) On smaller sizes, the leg of the Side Tie should be tucked under the corner of the Tie Pad as shown.



7) Wrap on both legs completely, snapping in the ends with thumb pressure.




8) Completed application of PREFORMED Side Tie and Tie Pad on a larger size conductor.




8a) Completed application of PREFORMED Side Tie and Tie Pad on a smaller size conductor.

HOT APPLICATION


Optional Tools which may be used to apply Tie Pad




1a) With either a Fixed Prong...



1b) ...or a Jumper Holding stick...




2) ...apply the Tie Pad to conductor, slit facing up, so that conductor does not come into direct contact with the insulator.




3) Tie Pad in position. Note that the conductor does not touch the insulator.

HOT APPLICATION

Optional Tools which may be used to apply Tie Pad




1a) With either a Fixed Prong...




1b) ...or a Jumper Holding stick...




2) ...apply the Tie Pad to conductor, slit facing up, so that conductor does not come into direct contact with the insulator.




3) Tie Pad in position. Note that the conductor does not touch the insulator.




- 4) The Side Tie application must be started to the lineman's right. Grasp the leg of the side tie with hold stick and place it on the conductor as shown, making certain the conductor is between the legs of the side tie.




- 5) Slide the Side Tie over the head of the insulator.




- 6) Side Tie in position to begin wrapping legs onto conductor.



- 7) Place the applicator Ring on the other leg. Pull the legs in opposite directions and start the wrapping motion.



8) Wrap on both legs of the Side Tie Completely, snapping in the ends with the Applicator Ring.



9) Completed hot stick application of Preformed Side Tie and Tie Pad.

GENERAL NOTES

- 1) Tools should not be used to snap the ends of legs into position during hand application.
- 2) Taps should not be made over the applied legs of the PREFORMED Side Tie.
- 3) PREFORMED Side Ties and Tie Pads are designed and manufactured for 54 mm - 76 mm and 112 mm Neck distribution insulators as noted on identification tape.
- 4) The following maximum lines angles should be observed:

	<u>Vertically Mounted</u>	<u>Horizontally Mounted</u>
MAX. Turning Angle	20°	15°
MAX. Sag Angle	15°	20°

SAFETY CONSIDERATIONS

- 1) For proper performance and personal safety be sure to select the proper size Side Tie before application.
- 2) Side Ties are precision devices. To ensure tight assembly, they should be stored in cartons under cover and handled carefully.
- 3) This application procedure is not intended to supersede any company construction or safety standards. This procedure is offered only to illustrate safe application for the individual. Failure to follow these procedures and restrictions may result in personal injury.
- 4) When working in the area of energized lines, extra care should be taken to prevent accidental electrical contact.
- 5) This product is intended for use by trained linesmen only. This product should not be used by any one who is not familiar with and trained in the use of it.




**PREFORMED
LINE PRODUCTS
(AUSTRALIA) PTY LTD**
A.B.N. 27 004 533 877

190 Power st. Glendenning, NSW Australia 2761
PO Box 106, Glendenning Business Centre, NSW Australia 2761
Phone: (02) 8805 0000 Fax: (02) 8805 0090
intl 61 2 8805 0000 intl 61 2 8805 0090
Email: plpaus@preformed.com.au
Web: www.preformed.com.au

NOTES

1. ALL DIMENSIONS IN MILLIMETRES.
2. TOLERANCES UNLESS OTHERWISE STATED:-
 - a. HOLE DIAMETRE ±0.5mm
 - b. LINEAR DIMS. UP TO 30mm ±1.5mm
 - c. LINEAR DIMS. OVER 30mm ±5% UP TO A MAX. OF 5mm.
3. BRACKETED DIMENSIONS DO NOT AFFECT INTERCHANGEABILITY OR COUPLING AND ARE FOR GUIDANCE ONLY.
4. MATERIAL TO AS1154
5. IDENTIFICATION MARKINGS:- AS SHOWN

PART No.	INSULATOR COLOUR CODE	CONDUCTOR COLOUR CODE	DIA
AWST-113A-54	RED	PURPLE	54
AWST-113-76	YELLOW	PURPLE	76
AWST-113A-76	YELLOW	PURPLE	76
AWST-113-112	BLUE	PURPLE	112



AWST-113A-54 PRODUCT TAPE COLOUR : PURPLE

3/4/1.75 ACSR OVER ARMOUR 54mm DIA NECK		AL CLAD STEEL SIDE TIE PART NO AWST-113A-54 W/O.....MM/YY
---	--	--

AWST-113-76 PRODUCT TAPE COLOUR : PURPLE

RANGE: 10.35-11.65 AAC, AAAC, ACSR 76mm DIA NECK		AL CLAD STEEL SIDE TIE PART NO AWST-113-76 W/O.....MM/YY
--	--	---

AWST-113A-76 PRODUCT TAPE COLOUR : PURPLE

RANGE: 10.35-11.65 AAC, AAAC, ACSR OVER ARMOUR 76mm DIA NECK		AL CLAD STEEL SIDE TIE PART NO AWST-113A-76 W/O.....MM/YY
---	--	--

AWST-113-112 PRODUCT TAPE COLOUR : PURPLE

RANGE: 10.35-11.65 AAC,AAAC,ACSR 112mm DIA NECK		AL CLAD STEEL SIDE TIE PART NO AWST-113-112 W/O.....MM/YY
---	--	--

A	CE	19.08.99	C	NA	09.05.11
CHK	DM	20.08.99	CHK	CC	28.06.11
INITIAL ISSUE		A9871			
ERF NO.A2856					

THIS DRAWING IS THE EXCLUSIVE PROPERTY OF PREFORMED LINE PRODUCTS (AUSTRALIA). REPRODUCTION THEREOF IS PROHIBITED AND IS TO BE USED ONLY WITH THE EXPRESSED PERMISSION OF THE COMPANY

PART No: AWST-113#-###		ALUMINIUM CLAD STEEL		SIDE TIE	
PASSED	PT	DATE	28.06.11		

	PREFORMED LINE PRODUCTS (AUSTRALIA) PTY. LTD.
SCALE	N.T.S.
DRAWING NUMBER	
084-019-RD	

TYPE TEST CERTIFICATE

PLP (AUSTRALIA) PTY LTD

ENGINEERING DEPARTMENT

DATE – 11TH NOVEMBER 2014

TYPE TEST REPORT NO: NATATT079
TEST REFERENCE NO: F14/122
PAGE 1 of 5

MECHANICAL STRENGTH TYPE TEST

ON:

ALUMINIUM CLAD STEEL SIDE TIE

PART NO. AWST-113-76

Testing Officer:  (Jose-elmer Simeon)

Approved by:  (Florian de Celis, Compliance Manager)

Date Approved: 26 / 11 / 2014

190 Power Street Glendenning NSW 2761 AUSTRALIA
Phone: 8805 0000, INTL (612) 88050000
Fax: 8805 0090, INTL (612) 88050090

Fittings and Accessories for Power and Communication.
Engineered Plastics and Extrusions.
Data Communication Products.