



8431 Murphy Drive
Middleton, WI 53562 USA


Telephone: 608.836.4400
Facsimile: 608.831.9279
www.intertek.com


Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address:	Preformed Line Products 660 Beta Drive Cleveland, OH 44143
Product Description:	POWER RAIL
Ratings & Principle Characteristics:	<u>Fire Class Resistance Rating:</u> - Class A for Steep Slope Flush-Mount Applications when using Type 1, Listed Photovoltaic Modules. Testing conducted with a 5" gap (distance between roof covering and bottom of PV module frame), therefore per UL 1703 (2014) the system can be installed with any gap allowed by the manufacturer's instructions.
Models:	Power Rail: P4, P6, P8 and P14
Brand Name:	N/A
Relevant Standards:	UL 2703 (Section 15.2 and 15.3) Standard for Safety Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels, First Edition dated Jan. 28, 2015 Referencing UL1703 Third Edition dated Nov. 18, 2014, (Section 31.2) Standard for Safety for Flat-Plate Photovoltaic Modules and Panels.
Verification Issuing Office:	Intertek Testing Services NA, Inc. 8431 Murphy Drive Middleton, WI 53562
Date of Tests:	08/27/2014 to 01/07/2015
Test Report Number(s):	101967185MID-001r1

This verification is part of the full test report(s) and should be read in conjunction with them. This report does not automatically imply product certification.

Completed by: Chad Naggs
Title: Technician II, Fire Resistance
Signature: 
Date: 03/30/2015

Reviewed by: Gregory Allen
Title: Engineering Team Lead, Openings
Signature: 
Date: 03/30/2015

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.